



From

Executive Engineer,  
Provincial Division No.2,  
PWD B&R Br., Rohtak.

To

The Principal,  
N.I.C. Sr. Sec. School,  
Assan (Rohtak).

Memo No. 815

Dated: 1-3-2018

**Subject:- Request for issuing the Building Safety Certificate against our school.**

**Reference: Your office letter No. NIC-PL-347 dated 19.02.2018.**

In this connection it is submitted that after visual inspection of the above school building at village Assan in Distt. Rohtak , it is found facts as under:

1. Building has been constructed in year 2005 ( as per statement provided by you).
2. Plinth level is about 2' above road level.
3. There is no crack visible in existing building.
4. Construction of building is frame type structure.

Hence it is certified that the school building is seems to be structurally safe.

DA/Nil

  
 Executive Engineer,  
 Provincial Division No.2,  
 PWD B&R Branch, Rohtak

*Devtki*  
 Manager  
 N.I.C. Sr. Sec. School  
 Assan (Rohtak)

*Gauty*  
 Principal  
 N.I.C. Sr. Sec. School  
 ASSAN (Rohtak)